

**Picosa Water Supply Corp.
Cross-Connection Control and
Backflow Prevention Program
Floresville, Texas**

Table of Contents

For

Cross-Connection Control and

Backflow Prevention Program

Section 1 – Introduction

- 1-1. Introduction
- 1-2. Principles
- 1-3. References

Section 2 – Definitions

2-1. General Words and Terms

- 2-1.1 Approved Air Gap Separation
- 2-1.2 Approved Backflow Prevention Method
- 2-1.3 Approved By-pass
- 2-1.4 Approved Check Valve
- 2-1.5 Approved Double Check Detector Assembly (DCDA)
- 2-1.6 Approved Double Check Valve Assembly (DC)
- 2-1.7 Approved Pressure Type Vacuum Breaker
- 2-1.8 Approved Reduced Pressure Backflow Prevention (RP) Assembly
- 2-1.9 Approved Spill Resistant Pressure Type Vacuum Breaker
- 2-1.10 Backflow
- 2-1.11 Backpressure
- 2-1.12 Backsiphonage
- 2-1.13 Board
- 2-1.14 Certification Classification
- 2-1.15 City
- 2-1.16 Contamination
- 2-1.17 Cross-Connection
- 2-1.18 Customer
- 2-1.19 Development Services Department
- 2-1.20 Director of Pipeline Inspections
- 2-1.21 Licensed Backflow Prevention Assembly Tester
- 2-1.22 Local Health Officer
- 2-1.23 Premises
- 2-1.24 Private Water Supply
- 2-1.25 Service Line
- 2-1.26 Water Service

Section 3 – Responsibilities

3-1. General

3-2. Health Agencies

3-3. Picoso Water Supply Corp.

3-4. Development Services Department,

3-5. Licensed Backflow Prevention Assembly Tester

3-5.1.1. Responsibility of Licensed Tester

3-5.1.2. Inspection and Repair

3-5.1.3. Procedure and Equipment

3-6. Customer Responsibility

Section 4 - Procedures

4-1. General

4-2. Type of Protection Required

4-2.1 Principle

4-2.1.1 Air Gap Separation

4-2.2 Criteria

4-2.3 Selection of Protective Device

- 4-2.3.1 Type of Business or Establishment - Picoso WSC Limits
- 4-2.3.3 Private Well Supply
- 4-2.4 Backflow Protection for Fire lines
 - 4-2.4.1 Classifications and Requirements for Backflow Protection on Fire lines
 - 4-2.4.2 Tri-Water System or Circulated Closed-Loop System
 - 4-2.4.3 Backflow Prevention Approved
- 4-2.5 Single Check Valve
- 4-3. Procedures on New Facilities**
 - 4-3.1 Building Permit
 - 4-3.2 Water Service Application
 - 4-3.3 Customer Service Inspections
- 4-4. Procedures on Existing Facilities**
 - 4-4.1 Inspection Procedure – Water Use Survey
 - 4-4.2 Development Services Department
 - 4-4.3 Picoso WSC Counter Services
 - 4-4.4 Picoso WSC Customer Service Department
- 4-5. Installation**
 - 4-5.1 Size of Backflow Prevention Assembly
 - 4-5.2 By-pass Policy
- 4-6. Non-compliance**
- 4-7. Records and Tests**
 - 4-7.1 Time Schedule
 - 4-7.2 Testing by Picoso WSC Personnel
- 4-8. Cross-Connection Control Liaison Committee**
- 4-9. Costs**
- 4-10. Process Flow Charts**
 - 4-10.1 Cross-Connection Control and Backflow Prevention Program Guidelines
 - 4-10.2 Customer Service Inspection Process

Appendix A – Backflow Prevention Assembly Installation Standards Appendix

B – Backflow Protection for Water Hauling Equipment-Mixing Tanks Appendix

C – Backflow Prevention Standard Drawing Information

Cross-Connection Control and Backflow Prevention Program

Guidelines

Picosa Water Supply Corp.
Floresville, Texas

Section 1 – Introduction

1-1. Introduction

The purpose of the Cross-Connection Control and Backflow Prevention Program is to provide guidelines for the implementation of the Picosa Water Supply Corp. Board of Trustees Regulations for Water Service, System Extension Service Line Installation and Criteria for Water Supply and Distribution within its service area as established by the Public Utility Commission of Texas and appropriate provisions of the Picosa WSC, all for the purpose of protecting the water supply of Picosa Water Supply from contamination by isolating within its customer's internal distribution system any contaminates which could Backflow into the public water supply system. Furthermore, the program establishes guidelines for the maintenance of a continuing program of Cross-Connection control and backflow prevention. Failure, refusal or inability on the part of the customer to comply shall constitute grounds for refusing or discontinuing water service. The desired control is one of containment of the actual or potential health hazard within the customer's premise.

1-2. Principle

The overall program is based on the experience obtained as a result of extensive field surveys which have revealed that after initial construction, uncontrolled Cross-Connections are made within many existing establishments to which Picosa Water Supply service is being provided. The desired control is one of containment of the actual or potential health hazard within the customer's premises. The hazard is to be contained through the use of an air gap separation or backflow protection assemblies. Assemblies will be installed between the outlet side of the water meter and before the first tap or tee. In some situations, backflow protection of the Picosa Water Supplies distribution system can be accomplished at the hazard point or through internal containment backflow prevention assemblies as outlined elsewhere in this program.

1-3. Reference

The following references are adopted and made a part of the Cross-Connection Control and Backflow Prevention Program.

- (1) The pertinent sections of the Picoso Water Supply Board of Trustees Regulations for Water Service, System Extensions and Service Line Installation, which prohibit a direct connection between the Picoso Water Supply and a customer service line including a Cross-Connection potentially resulting in a source of contamination of the Picoso Water Supply. shall require appropriate backflow prevention protection for those facilities as provided for in the Picoso Water Supply Corp. Utility Service Regulations and Picoso WSC Backflow Prevention Program where a potential health hazard exists. Picoso Water Supply shall immediately discontinue service to any property where any unapproved connection or Cross-Connection exists, and service shall not be reestablished until the Picoso Water Supply determines the unsatisfactory condition has been corrected.
- (2) Those pertinent sections of the Picoso Water Supply, Utility Service Regulations and Picoso Backflow Prevention Program in its Extra-territorial Jurisdiction stipulate
- (3) The type of backflow prevention assembly, and the condition under which such an assembly shall be installed. These assemblies are outlined in Section 4 of this Program.
- (4) Picoso Water SC Code, Section 34-40. Cross-Connections with Water Mains Prohibited, which states, “(a) It shall be unlawful for any person to make or to maintain any Cross-Connection within the city or to allow any Cross-Connection to exist at any place under the control of any person. (b) The term Cross-Connection, as used in this section, is defined as any mechanical union or any hydraulic union which, under any condition, might pass water into the water supply system of the PicosoWSC from any other source.”
(Code 1950, § 62-14; Code 1959, § 41-22)
- (5) Picoso WSC Code, Section 34-41. Disconnection for noncompliance, which states, “It shall be the duty of the manager of the Picoso Water Supply Corp. of the disconnect from any place where the provisions of this article are violated, whether inside or outside the Picoso WSC.”(Code 1950, § 62-15; Code 1959, § 41-23)
- (6) Picoso Water Supply Corp., Section 24.1. International Plumbing Code, Paragraph (a) which states, “The 2012 edition (latest revision) of

the International Plumbing Code of the International Code Council and, as amended hereinafter, is hereby adopted as the Plumbing Code of Picoso WSC.” The International Plumbing Code 2012 chapter 6, section 608.1 and amendment’s, Protection of Potable Water states: *A potable water supply system shall be designed, installed and maintained in such a manner so as to prevent contamination from non-potable liquids, solids or gases being introduced into the potable water supply through cross-connections or any other piping connections to the system. Backflow preventer applications shall conform to Table 608.1, except as specifically stated in Sections 608.2 through 608.16.10.*

Chapter 6, Section 608.1; Protection of Potable Water supply Cross-connection control shall be provided in accordance with the provision of this chapter. No person shall install any water operated equipment or mechanism, or use any water treating chemical or substance, if it is found that such equipment, mechanism, chemical or substance may cause pollution or contamination of the domestic water supply. Such equipment or mechanisms may be permitted only when equipped with an approved backflow prevention device or assembly.

Chapter 34, Article VI, Division 8. Backflow Prevention- Section 34-1075 through Section 34-1081

- (7) Occupational Safety & Health Administration - Federal Register, number 202 Part 2 Page 22234 sub-parts J General Environmental Control 1910.14.1 Sanitation which states that “(b) Water Supply- (2) Non-potable Water (ii) there shall be no Cross Connection; open or potential, between system furnishing Non potable water. (iii) Construction shall be such as to prevent backflow of containment water into a potable water system.”
- (8) U.S. Environmental Protection Agency - Cross-Connection Control Manual (1972 Edition or latest revision) EPA
- (9) RG 195 (2012 edition Texas Commission on Environmental Quality (TCEQ) Rules and Regulations for Public Water Supply Systems, Sec. 290.44 (h) (1) Backflow, Siphonage - No water connection from any public drinking water supply system shall be allowed to any residence or establishment where an actual or potential contamination hazard exists unless the public water facilities are protected from contamination. The containment air gap is sometimes impractical and instead, reliance must be placed on individual “internal” air gaps or mechanical backflow prevention. Under these conditions, additional protection shall be required at the meter in the form of a backflow prevention assembly (in accordance with TAC 25 Sec. (F) 4, 5 #14 229.61- 229.175 AWWA

Standards C510 and C511, and AWWA Manual M14, USC 10th edition) on those establishments handling substances deleterious or hazardous to the public health. The water purveyor need not require backflow protection at the water service entrance if an adequate Cross-Connection control program is in effect that includes an annual inspection and testing by a licensed backflow prevention assembly tester. It will be the responsibility of the water purveyor to ensure that these requirements are met.

Cross-Connection Control and Backflow Prevention Program

Guidelines

Picosa Water Supply Corp.
Floresville, Texas

Section 2 – Definitions

2-1. General Words and Terms

2-1.1. Approved Air Gap Separation is the unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe or faucet supplying water to a receiving tank and the flood rim of the tank. An approved air gap separation shall be at least twice the diameter of the supply pipe measured vertically above the overflow rim of the vessel, and in no case shall the gap be less than one inch.

2-1.2. Approved Backflow Preventers have been reviewed and approved by Picosa WSC, including the following types of Backflow Protection: approved air gap separation, approved reduced pressure principle backflow prevention assembly, approved double check valve assembly, approved spill resistant and approved pressure-type vacuum breaker.

2-1.3. Approved By-pass is a connection from the Picosa WSC side of an approved device to the customer side of the assembly for the purpose of diverting the water around the backflow preventer while it is being repaired or replaced. All By-passes on backflow prevention devices will themselves include provisions for backflow prevention as described within this program.

2-1.4. Approved Check Valve is a check valve that seats readily and completely. It must be carefully machined to save free moving parts and assure water tightness permitting no leakage in a direction reverse to the normal flow. The valve must be weighted or spring loaded to one psi in the direction of flow. The face of the closure element and valve seat must be of bronze composition or other non-corrodible material which will seat tightly under all prevailing conditions of field use. Pins and bushings shall be of bronze or other non-corrodible, non-sticking material, machined for easy, dependable operation. The closure element, normally referred to as a clapper, shall be internally weighted or otherwise internally equipped to promote rapid and positive closure in all sizes where this feature is obtainable.

2-1.5. Approved Double Check Detector Assembly (DCDA) The term “double check-detector backflow prevention assembly” shall mean a specifically designed assembly composed of a line-sized approved double check valve assembly with a By-pass containing a specific water meter and an approved double check valve assembly. The meter shall register accurately for only very low rates of flow up to three gpm (gallons per minute) and shall show a registration of all rates of flow. This assembly shall only be used to protect against a non-health hazard (i.e., pollutant). The DCDA is primarily used on fire sprinkler systems. The entire assembly shall meet the design and performance specifications and full approval, lab and field, of a recognized and approved testing agency for backflow prevention assemblies, e.g., University of Southern California’s Cross-Connection Control or American Water Works Association.

2-1.6. Approved Double Check Valve Assembly (D/C) is an assembly composed of two single, independently acting, approved check valves, including resilient seating shut-off located at each end of the assembly and suitable connections for testing the water tightness of each check valve. The entire assembly shall meet the design and performance specifications and full approval, lab and field, of a recognized and approved testing agency for backflow prevention assemblies, e.g., University of Southern California’s Cross-Connection Control or American Water Works Association.

2-1.7. Approved Pressure Type Vacuum Breaker is an assembly containing a single-loaded check valve and an air inlet valve which shall admit air whenever the pressure within the body of the assembly is reduced so that there is a tendency toward backsiphonage. The body of the assembly must be equipped with two tight closing shut off valves. One immediately upstream from the body and one immediately downstream of the body, and two properly located test cocks. It is designed to operate under constant pressure for long periods of time without inoperative, making it possible to isolate a lawn sprinkler line from the potable system. It must be installed so as to never be subject to backpressure. The entire assembly

shall meet the design and performance specifications and full approval, lab and field, of a recognized and approved testing agency for backflow prevention assemblies, e.g., University of Southern California's Cross Connection Control or American Water Works Association.

2-1.8. Approved Reduce Pressure Backflow Prevention (RP) Assembly is an Assembly of two independently operating approved check valves with an automatically operating differential relief valve between the two check valves, resilient seating shut-off valves on either side of the assembly, plus four properly located test-cocks for the testing of the check and relief valves. The entire assembly shall meet the design and performance specifications and full approval, lab and field, of a recognized and approved testing agency for backflow prevention assemblies, e.g., University of Southern California's Cross-Connection Control or American Water Works Association. The assembly shall operate to maintain the pressure in the zone between the check valves at a level two psi less than the pressure on the public water supply side of the device. At cessation of normal flow, the pressure between the check valves shall be two psi less than the supply pressure. In case of leakage of either check valve, the differential relief valve shall operate to maintain this reduced pressure by discharging to the atmosphere. When the inlet pressure is two psi or less, the relief valve shall open to the atmosphere. To be approved, these devices must be installed above ground.

2-1.9. Approved Spill Resistant Pressure Type Vacuum Breaker is an assembly containing a single-loaded check valve and an air inlet valve which shall admit air whenever the pressure within the body of the assembly is reduced so that there is a tendency toward backsiphonage. The body of the assembly must be equipped with two tight closing shut-off valves, one immediately upstream from the body and one immediately downstream of the body and one properly located test cock and vent valve. It is designed to operate under pressure for long periods of time without becoming inoperative, making it possible to isolate a lawn sprinkler line from the potable system. It must be installed such that it could never be subject to backpressure. The entire assembly shall meet the design and performance specifications and full approval, lab and field, of a recognized and approved testing agency for backflow prevention assemblies, e.g., University of Southern California's Cross-Connection Control or American Water Works Association.

2-1.10. Backflow within the scope of this program is the reverse flow of water through a service connection, i.e., flowing from the customer's side of the service connection into the distributing pipelines of the potable water system. Backflow may occur under either backpressure or backsiphonage conditions.

2-1.11. Backpressure is the pressure in the customer's system that exceeds that in the public water system.

2-1.12. Backsiphonage occurs when the pressure in the public water system becomes less than that of the customer's system due to a vacuum or partial vacuum in the public system.

2-1.13. Board is the Picoso Water Supply Corp. Board of Trustees

2-1.14. Licensing Classification is divided into the following categories and the testers are not considered to be employees, agents or representatives of Picoso WSC.

(1) Backflow Prevention Assembly Tester means qualified to test any type or make of backflow prevention device. (Not to include testing on fire line devices)

(2) A licensed backflow prevention assembly tester may test and repair assemblies on a fire protection sprinkler system if they are permanently employed by a fire sprinkler contractor registered through the State Fire Marshal's Office. One exception is that an employee of the property owner, who is a licensed backflow prevention assembly tester, may test an assembly located on the employer's property if authorized by the property owner and the employer takes full responsibility for the required fire protection measures during the test or repair and the responsibility for the correct restoration of the fire protection system. An employee of a registered fire sprinkler contractor performing the required testing of a backflow prevention assembly must be a licensed backflow prevention assembly tester. See 28 TAC §20.44(h) (4) (A) (ii) and Texas Insurance Code Article 5.43- 3 Sec 2.

2-1.15. Picoso Water Supply Corp. Floresville, Texas.

2-1.16. Contamination is the presence of any foreign substance (organic, inorganic, radiological or biological) in water which tends to degrade its quality so as to constitute a health hazard or impair the usefulness of the water.

2-1.17. Cross-Connection an unprotected actual or potential connection, mechanical or hydraulic union between a potable water system and a recycled or other non-potable water system that would allow non-potable water to pass into the potable water supply.

2-1.18. Customer is any person to whom water is sold or furnished from the City water supply by the Picoso WSC . (Can mean either owner or lessee).

2-1.19. Development Services Department is the department for all permitting services for the Picoso WSC.

2-1.20. Licensed Backflow Prevention Assembly Tester is any person that has received authorization from the Texas Commission on Environmental Quality (TCEQ) by successfully completing a TCEQ approved certification school. The tester will be approved to test assemblies as outlined in section 2-1.26. Manufacturer's representatives who have completed a TCEQ approved Certification School will be accepted as a certified backflow prevention assembly tester for the assemblies produced by the manufacturer they represent. The Director of Pipeline Inspections will maintain a current list of approved testers and will honor any request for the same. The applicant must renew his license with TCEQ and copy the Picoso Water Supply Corp. every three years. However, the tester may be removed from the "approved list" by Picoso WSC for improper testing or reporting for a period of one year. Additionally, the tester could receive possible fines from TCEQ based on the severity of the violation.

2-1.21. Premise is an integrated land area including improvements thereon undivided by public thoroughfares or water distribution mains of the Picoso Water Supply Corp. and where all parts of the premises are operated under the same management.

2-1.22. Private Water Supply is any water supply including a well on or available to the premises other than the public water supply. These auxiliary waters may include water from another purveyor's public water supply or any natural source such as a well, spring, river, pond, rainwater, etc.

2-1.23. Service Line is a pipe extending from a water distribution main installed in a permitted location adjacent to the property of a customer and terminating at the Picoso WSC water meter for the purpose of providing water to a customer for ordinary metered water service. Service line connections also include water service connections from fire hydrants and other temporary or emergency water service lines from the public water system.

2-1.24. Water Service is the complete range of activities of Picoso WSC in combination with total facilities utilities used by Picoso WSC to provide for the delivery of potable water and water for fire protection in adequate quantity and pressure to the premise of the customer.

Cross-Connection Control and Backflow Prevention Program

Guidelines

Picoso Water Supply Corp.
Floresville, Texas

Section 3 – Responsibilities

3-1. General

The implementation of a program for the effective control of Cross connections and backflow prevention requires the full cooperation of all concerned: the state and local health agencies, the water purveyor, the Planning and Development Services Department of Building Inspections, the Licensed Backflow Prevention Assembly Tester and the customer.

3-2. Health Agencies

The “Rules and Regulations for Public Water Systems” of the Texas Commission on Environmental Quality govern the design, construction, operation and maintenance of Public Water Supplies.

290.44 (h) Backflow, Siphonage

“No water connection from any public drinking water supply system shall be allowed to any residence or establishment where an actual or potential contamination hazard exists unless the public water facilities are protected from contamination.”

The containment air gap is sometimes impractical and instead, reliance must be placed on individual “internal” air gaps or mechanical backflow prevention devices. Under these conditions, additional protection shall be required at the meter in the form of a backflow prevention assembly (in accordance with AWWA standards C510 and C511, and AWWA manual M14) and (USC 10th Edition) on those establishments handling substances deleterious or hazardous to the public health. The water purveyor need not require backflow protection at the water service entrance if an adequate Cross-connection control program is in effect that includes an annual inspection.

290.44 (h) (2)

“No water connection from any public drinking water supply system shall be made to any condensing, cooling or industrial process or any other system of non-potable usage over which the public water supply system officials do not have sanitary control, unless the said connection is made in accordance with the requirements of paragraph (1) of this subsection. Water from such systems cannot be returned to the potable water supply”

290.44 (h) (4)

“All backflow prevention assemblies that are required according to this section and associated table located in 290.47(i) of this title shall be tested

upon installation by a recognized backflow prevention assembly tester and certified to be operating within specifications. Backflow prevention assemblies which are installed to provide protection against health hazards must also be tested and certified to be operating within specifications at least annually by a recognized backflow assembly tester.

290.44 (h) (4) (B)

“Gauges used in the testing of backflow prevention assemblies shall be tested for accuracy annually in accordance with the University of Southern California’s Manual of Cross-connection Control or American Water Works Association Recommended Practice for Backflow Prevention and Cross-connection Control (Manual M-14). Public water systems shall require testers to include test gauge serial numbers on “Test and Maintenance” report forms and ensure testers have gauges tested for accuracy.

290.44 (h) (4) (C)

“A Test Report must be completed by the recognized backflow prevention assembly tester for each assembly tested. The signed and dated original must be submitted to the public water supplier for record keeping purposes. Any form which varies from the format specified in Appendix F of this title (relating to Backflow Prevention Assembly Test and Maintenance Report) must be approved by the executive director prior to being placed in use.”

290.44 (h) (1) (B) (ii)

“Copies of all such inspection and test reports must be obtained and kept on file by the water purveyor.”

290.44 (h) (5)

“The use of a backflow prevention assembly at the service connection shall be considered as additional backflow protection and shall not negate the use of backflow protection on internal hazards as outlined and enforced by local plumbing codes.”

Texas Commission on Environmental Quality (TCEQ) is the primary enforcing agency of the “Rules and Regulations” for Public Water Systems for all public water systems in the state of Texas.

3-3. Picoso Water Supply Corp.

Picoso Water Supply Corp has the responsibility of providing its customers with drinking water in accordance with its status as a Public Water System.

Picosa WSC responsibility begins at the production facilities and includes all of the public distribution systems, including the service line and ends at the point of delivery to the customer's water system which is the customer's side of the water meter. To ensure adequate protection in individual cases, the Director of Pipeline Inspections or his representative is required to determine the degree of hazard to the public potable water system. When it is determined that a backflow prevention assembly is required for the protection of the public water system, the water purveyor will require the customer, at his expense, to properly install an approved backflow prevention assembly at each service connection and/or at the hazard point to be tested annually or more often in those instances where successive inspections indicate repeated failure, and to properly repair and maintain such assembly or assemblies. The Director of Pipeline Inspections will establish a Cross-connection Control Group within the Engineering Department for the purpose of implementing and monitoring this program. The Backflow Prevention Supervisor will administer the program and will act as the Picosa WSC representative on the Cross-connection Liaison Committee. As stated in definition 2-1.25, the Director of Pipeline Inspections shall maintain a current list of Approved Backflow Prevention Assembly Testers. It shall be the responsibility of the Picosa WSC Backflow Prevention Supervisor to enforce the Cross-connection Control regulations by directing competent inspections of installations of approved backflow prevention assemblies, in accordance with these guidelines on both new and existing facilities. He shall assure that proper records are maintained on all installations of approved backflow prevention assemblies, in accordance with these guidelines on both new and existing facilities. He shall assure that proper records are maintained on all installations and shall initiate action as appropriate to prohibit or discontinue service to any customer who maintains actual or potential sanitary health hazards in his internal potable water system (downstream from the meter) or whose plumbing is susceptible to Cross-connections unless adequate protection against backflow is provided.

3-4. Development Services Department of the Picosa Water Supply Corp.

The Plumbing Inspection Section of the Development Services Department has the responsibility to assure compliance with all Plumbing Codes and amendments pertaining to Cross-connections, i. e., and proper installation of the customer's building plumbing including the connection line to the public potable water supply. It is the responsibility of the Development Services Department to coordinate all building permit approvals with the Picosa Water Supply for the total containment program. The Director of Building Inspections will appoint a representative to the Cross-connection Control Liaison Committee.

3-5. Licensed Backflow Prevention Assembly Tester 3-5.1.

Responsibility of Licensed Tester

When employed by a customer, a Licensed Backflow Prevention Assembly Tester is responsible for the test, repair, overhaul and maintenance of backflow prevention assemblies.

3-5.2.1 Inspection and Testing of backflow prevention assemblies

Picosa WSC, Planning and Development Services Department, Plumbing Division. As per 2012 International Plumbing Code and Local Amendment 608.13.12 The premise owner or responsible person shall have the backflow preventer assembly tested by a licensed backflow assembly tester at the time of installation, repair or relocation and tested and inspected at least on an annual schedule thereafter, or more often when required by the public water system that provides water to the property where the backflow prevention assembly is installed. . All annual inspection and testing shall be performed in accordance with Chapter 34, Article VI, Division 8, of the Picosa WSC Floresville, Texas. The periodic testing shall be performed in accordance with the University of Southern California's procedures by a tester qualified in accordance with those standards.

312.10 Inspection and testing of backflow prevention assemblies

Inspections and testing shall comply with Sections 312.10 and 312.10.2

312.10.1 Inspections

Annual inspections shall be made of all backflow prevention assemblies and air gaps to determine whether they are operable.

312.10.2 Testing

Reduced pressure principle backflow prevention assembly, double check valve, pressure vacuum breaker, reduced pressure principle backflow prevention assembly detector, double check detector assembly , and spill resistant vacuum breaker and hose connection backflow preventers shall be tested at the time of installation, immediately after repairs or relocation and at least annually. The testing procedures shall be performed in accordance with one of the following standards: ASSE 5013, ASSE 5015, ASSE 5020, ASSE 5047, ASSE 5048, ASSE 5052, ASSE 5056, CSA B64.10 or CSA B64.10.1.

3-5.2.2 Inspection and Repair

The licensed tester will be responsible for making competent inspections and repairing or overhauling backflow prevention assemblies and making reports of such repair to the customer in accordance with the Test and Maintenance Report Form. He/she shall include in the report a list of materials or replacement parts used, and he/she shall be equipped with and

be competent to use all necessary tools, gauges, manometers and other equipment necessary to properly test, repair and maintain backflow prevention assemblies. It will be his/her responsibility to assure that parts recommended by the manufacturer of the assembly being repaired are used in the repair or replacement of backflow prevention device parts. It is extremely important that Picoso WSC be made aware of any malfunctioning assembly within 24 hours.

3-5.2. Procedure and Equipment

It will be the licensed tester's responsibility not to change the design, material, or operational characteristics of an assembly during repair or maintenance without prior approval of Picoso WSC. All work performed by his/her assistants shall be performed in his/her presence and under his/her jurisdiction. Each applicant for certification as a tester of backflow prevention assemblies shall furnish evidence to show that he/she has available the necessary tools and equipment to properly test such assemblies. The serial number of his/her test kit shall be on record with the Picoso Water Supply and the test gauge must be tested when purchased and annually or more frequently as required by Picoso WSC. The gauge must be maintained to a + or - .2 PSID accuracy. The tester shall be responsible for the competency and accuracy of all tests and reports prepared by him/her and for the work done by any persons under his/her jurisdiction. In addition, gauge accuracy can only be achieved by a certified gauge Manufacturer Representative or an ABPA Certified Proctor. Neither entity can test one's own gauges or for any other affiliated agency.

3-6. Customer Responsibility

The customer has the primary responsibility of preventing contaminants from entering his/her potable water system(s) or the public potable water system. The customer starts at the point of delivery from the public potable water system, and includes his/her complete internal water system. The customer, at his/her own expense, shall install, operate, test and maintain approved backflow prevention assemblies as required by the Picoso Water Supply Corp. Following any repair or overhaul of an assembly, the customer shall have it tested to ensure that it is in proper operating condition. Re-piping and relocation of an assembly shall have prior approval of the PicosoWSC and shall be followed by re testing. Tests, maintenance and repair of backflow prevention assemblies shall be made by a licensed Backflow prevention assembly tester. The customer shall maintain accurate records of tests and repairs to backflow prevention assemblies and provide Picoso WSC with copies of such records via the Test and Maintenance report form. Questions can be directed to:

Backflow Section
Picos Water Supply Corp.
3274 FM-2579
Floresville, Texas 78114
(830)393-4424

Cross-Connection Control and Backflow Prevention Program

Guidelines

Picos Water Supply Corp.
Floresville, Texas

Section 4 – PROCEDURES

4-1. General

The procedure outlined herein is based on the afore-mentioned principle of containment of the potential or actual health hazard within the customer's premises. Proposed deviations or exceptions may be submitted to the Picos Water Supply Corp.. Should a customer refuse the right of entry of the Picos Water Supply Corp. representative(s) for the purpose of a water use survey or backflow prevention assembly inspection, the Picos WSC must assume maximum hazard and therefore require the highest degree of protection on such a customer's service line.

4-2. Type of Protection Required

4-2.1. Principle

It is to be recognized that Cross-connections vary widely in degree of health hazard. The degree of protection and the type of protection deemed necessary to prevent backflow and possible contamination of the Picos WSC Criteria concerning Cross-connection Control and Backflow Prevention is further outlined in this section. Backflow may occur under

many different pressure differentials varying from so-called vacuum to very high pressures. The protection afforded by an assembly depends upon its type and on its proper installation, testing and maintenance.

4-2.1.1. Air Gap Separation

An air gap installation separating the Picoso Water Supply Corp. supply from the customer's internal water system is acceptable in all situations listed in these procedures so long as it is properly maintained. Initial installation of this type that was originally made in accordance with this program may be subsequently changed. As these separations are easily eliminated or by-passed, it shall be the prerogative of the Picoso Water Supply Director of Pipeline Inspections to perform field surveys and to explicitly specify the additional protection of a mechanical assembly. For example, this would result in the case of a repeated violator of air gap separation standards. The air gap separation must be located as close as possible to the water meter, and normally all piping between the meter and receiving tank shall be entirely visible.

4-2.2 Criteria

The selection of an appropriate backflow prevention assembly depends upon the degree of health hazard involved and will be based on the following general criteria:

- A. Whether or not the assembly could ever be subject to backpressure due to the customer's internal pumping pressures or elevation differentials.
- B. The nature of the contaminating material under the most critical circumstances.
- C. The extent to which additions may be made to the plumbing systems at a later date which would affect the initial selection of the assembly.
- D. The frequency with which a water supply could be exposed to a hazardous condition.
- E. The degree of protection of the water supply as provided by the local plumbing code and as enforced by the Picoso WSC, Planning and Development Services Department, Plumbing Division.

F

Picoso Water Supply Director of Pipeline Inspections, acting either personally or through Picoso WSC Pipeline Inspection Department field representative, shall retain the final decision in individual cases. He may, in formatting his decision, obtain advice and recommendation of the Cross-connection Control Liaison Committee.

It is essential that all types of establishments listed below provide for the “containment” of contamination within their premise by an air gap separation between the meter and the first tap or tee by having each of the internal plumbing facilities are properly air gapped. If the “containment” air gap is impractical and reliance instead is placed on individual “internal” air gaps or vacuum breakers, the Director of Pipeline Inspections has the prerogative of requiring additional protection in the form of either a reduced pressure principle backflow prevention assembly on establishments handling substances deleterious to health, or a double check valve assembly on those handling substances of which if backflow occurred into the potable water lines, would cause the water to be aesthetically objectionable. In limited instances, provisions for total containment backflow protection shall be reviewed to allow the backflow prevention assembly to be installed on an internal branch line. An example of Internal Containment backflow protection would be a combination fire and domestic water service from the Picoso water main. The containment, domestic backflow protection would be installed immediately after the fire line tee. Additionally, the fire line shall be provided with backflow protection in accordance with 4-2.4 Backflow Protection for Fire Lines. Those establishments/businesses which can be considered for internal containment backflow protection are noted as such in the criteria list, 4-2.3.1. The Director of Pipeline Inspections shall have final determination when internal containment backflow protection will be allowed.

4-2.3 Selection of Protection Method

The type of device or assembly selected is based on the determined degree of health hazard. It will be determined by the Backflow Prevention Supervisor to require this added protection and shall be exercised after an individual review of each case. This review will include an on-site inspection of the establishment by his/her representative.

4-2.3.1 Type of Business or Establishment – Inside and Outside Picoso WSC Device or Assembly Required

- A/G - Air Gap Separation
- R/P - Reduced Pressure Principle Backflow Prevention Assembly D/C
- Double Check Valve Assembly
- DCDA - Double Check Detector Assembly
- P.T.V.B - Pressure Type Vacuum Breaker
- S.V.B. -Spill/Resistant Vacuum Breaker

Type of Establishment/ Business	Protection Required	Type of Establishment/ Business	Protection Required
--	----------------------------	--	----------------------------

<p>Apartments/ Condominiums</p> <p>Four Stories or more OPTION (Containment at meter or Internal Containment required at each building)</p>	A/G-DCVA-R/P	<p>Photo Lab (More Than Two Machines)</p>	A/G or R/P
<p>Auxiliary Water Supply</p> <p>Recycled, Wells, Rain Harvesting etc.</p>	A/G or R/P	Plating Plant	A/G or R/P
<p>Belted Meter Installation</p> <p>(By Individual Review)</p>	A/G-DCVA- R/P	Power Plant	A/G or R/P
<p>Commercial Building – Four Stories or more OPTION (Containment at meter or Internal Containment required at each building)</p>	A/G-DCVA-R/P	<p>Commercial Businesses or Establishments (By Individual Review)</p>	A/G -DCVA-R/P
<p>Car Wash (internal containment option-within two feet of main water service entry into car wash)</p>	A/G or R/P	<p>Restricted Establishments (Military/AirFields)</p>	A/G or R/P
<p>Fire Line (With Chemical Additive)</p>	A/G or R/P	Sewage Treatment Plants	A/G or R/P

<p>Fire Line (With Fire Hydrant – see 4.2.4.1)</p>	A/G or DCDA		<p>R/V Park (By Individual Review)</p>	A/G or R/P
<p>Fire Line (Without Fire Hydrant)</p>	A/G or DCVA		<p>Gated Community Dedicated Services (By Individual Review)</p>	A/G or R/P

Food Processing/Packaging Plant	A/G or R/P		Cooling Tower, Heat Exchangers, Chillers	A/G or R/P
Greenhouse, Landscape and or Grass Farms	A/G or R/P		Stock Yard/Farm & Ranch (By Individual Review)	A/G or R/P
Hospital/Dental/Medical Facility (By Individual Review)	A/G or R/P		Schools-Colleges Universities (elementary school individual review)	A/G or R/P
Jail	A/G or R/P		Transportation Terminal	A/G or R/P
Laboratory – Chemical or Clinical	A/G or R/P		Wholesale Connections (Planned Unit Develop)	A/G or R/P
Laundry and Dry Cleaning Plants-Retail (Internal Containment Optional)	A/G or R/P		Reduction/Rendering Plant	A/G or R/P
Lawn Irrigation Systems (With Sanitary Sewer)	A/G -D/C-PTVB SVB		Petroleum Processes and Storage Plant	A/G or R/P
Lease Space (two or More Single Service) Containment/Internal Containment Option-Inside City Limits	A/G or R/P		Beauty Saloon/ Parlors With Foot Spas (Individual Review)	A/G or R/P

Mortuary	A/G or R/P	Veterinary Clinic (Individual Review)	A/G or R/P
----------	-------------------	--	-------------------

Note: Other types of establishments or businesses may require protection via air gaps or backflow prevention assemblies depending on the equipment and/or plumbing arrangements utilized therein. These shall be considered individually, at the discretion of the Supervisor of Backflow Prevention or his/her representative.

4-2.3.2 Private Well Supply

Where a private well supply exists in addition to an active Picoso WSC service, the Texas Commission on Environmental Quality “Rules and Regulations,” are applicable as follows:

***Picoso Water Supply with Approved Air Gap or
Private Well On-site***

Reduced Pressure Principle Assembly (Located right after the meter inside property line outside of easement)

4-2.4 Backflow Protection for Fire Lines

Fire Flow Meter: Installation will be looked at upon individual review In the interest of protecting the public’s potable water supply from possible contamination, effective March 15, 1999, the Picoso Water Supply Corp. began requiring backflow protection on all new fire-line installations. As in other situations encountered in Cross-connection control, the degree of backflow protection necessary for a particular fire protection system will depend on specific conditions present. Pressure losses across backflow prevention assemblies must be accompanied in the design or redesign of the fire protection system if it is to function properly. This factor is particularly important when redesigning existing fire protection systems. All backflow prevention assemblies shall be University of Southern California’s Foundation for Cross-connection Control and Hydraulic Research Laboratory listed. Backflow prevention assemblies detailed herein shall be constructed in accordance with the provisions set forth in the Picoso WSC Backflow Prevention Assembly Installation Standards, revised in October, 2006, or latest revision.

Stagnant Water Rule: In the interest of protecting the public, it was determined that any water service that remains in a static condition from property line to ending point that exceeds 100 linear feet would have the appropriate backflow prevention device installed within said footage.

4-2.4.1 Classification and Requirements for Backflow Protection on Firelines TYPE OF

FIRELINE REQUIRED PROTECTION

- A. Fireline with no chemical No Requirement
Additive and no additional
Water supply- less than 100'
total linear pipe footage of
a fire system to the most
remote head

- B. Fireline with no chemical Double Check Valve Assembly Additive and
no additional
Water supply- greater than 100'
total linear pipe footage of
a fire system to the most
remote head*

- C. Fireline with fire hydrant no chemical Double Check Detector Assembly
Additive and no additional
Water supply- greater than 100'
total linear pipe footage of
a fire system to the most
remote head

- D. Fireline with fire hydrant- no chemical Detector Check Valve Picoso WSC
Additive and no additional water supply- Standard Drawing
Less than 100' total linear pipe footage
to the fire hydrant

- E. Fire protection system Air Gap Separation or Reduced Utilizing chemical
additives** Pressure Principle assembly

- F. Fire protection system with access to Air Gap Separation or Reduced An
auxiliary water supply ** Pressure Principle assembly

*Systems over 50% or more renovations and those systems installing booster pumps shall include provisions to protect the potable water supply from stagnant water as outlined in Section 4-2.4.1.

**Systems with chemical loops and/or foam injection shall require a reduced pressure principle backflow prevention assembly at the loop or foam injection point. However, an

expansion chamber or relief valve will have to be installed to compensate for thermal expansion in accordance with the fire codes. The installation of reduced pressure principle assemblies for containment backflow protection on fire lines should be avoided and installed only in situations where chemical injection occurs prior to any taps or tees.

***Existing chemical loops and systems with access to an auxiliary water supply shall be retrofitted with approved backflow protection.

Note: On a project that reflects ingress/egress it will be looked at as right of way when determining the 100' stagnant water rule on fire line placement. Line of Demarcation will be determined upon individual review.

4-2.4.2 Tri-Water System or Circulated Closed-Loop System

“Tri-Water” or “Circulated Closed Loop System” will not be permitted, i.e., combination fire line, heating and cooling.

4-2.4.2.1 Full Flow Testing and/or Backflow Prevention Assembly repair Requirements for Fire Lines

Picosa WSC requires backflow prevention assemblies installed on fire lines to be in accordance with all local fire codes and NFPA standards. In the event of a repair, the assembly shall be cleaned and rubber parts replaced when deemed necessary by the backflow prevention assembly tester and/or manufacturer. A full flow test should be performed to make sure the assembly will open properly during a fire event. Assemblies should be tagged by the tester to indicate the last repair date and that a full flow test was performed. The Backflow Prevention Section shall monitor these assemblies to ensure provisions are met as established above – “Full Flow Testing and/or repair Requirements for Fire lines.”

Exception: If within a five year period, the assembly has been completely disassembled and cleaned (repair parts replaced if necessary), the five-year tear-down period will begin at that time. In the annual testing process, a backflow prevention assembly found to be malfunctioning should be completely torn down, repaired and a flow test should be performed.

4-2.4.2.2 Test and Maintenance Report Form for Fire Line Backflow Prevention Assemblies

Test and Maintenance Report Forms (T&M) forms used by fire line testers shall include statements which indicate the system has been placed back in operation upon completion of test. Additionally, the (T&M) form shall have a statement for the tester to check off which indicates a flow test was performed within the past 12 months as established in NFPA 25 Section 9.6.2.2.

The tester will attach full flow documentation to the (T&M) when submitted to the Picoso WSC Backflow Prevention Section.

4-2.4.3 Backflow Prevention Approval

Backflow preventer approval shall be obtained from the Picoso WSC (830)393-4424 and the Pipeline Inspection Department - Backflow Prevention Section of the Picoso WSC (830)393-4424 prior to installation. The installation shall conform to the attached guidelines. Please direct any questions or comments to the Picoso WSC Pipeline Inspection Department – Backflow Prevention Section (830) 393-4424.

4-2.5 Single Check Valve

The single check valve is not considered to be an approved backflow prevention assembly and is used in limited instances such as for directional flow control.

4-3 Procedures On New Facilities

The requirement for installation of a backflow prevention assembly by a new customer of the Picoso WSC shall be issued in conjunction with his/her request for water service from the Picoso WSC Counter Services Division or with his/her application through the Planning and Development Services Department of Building Inspections for a building permit. In either case, field inspection of the premises and some discussion with the owner or his/her representative may be necessary to determine what the actual or potential health hazards are and therefore what the assembly requirement will be.

4-3.1 Building Permit

All mechanical layouts or building plans submitted to the Picoso WSC Development Services Department will be reviewed by a plumbing inspections division representative to assure compliance with the state's plumbing code. All mechanical layouts or plans will be stamped by the plumbing inspections department to indicate containment. Backflow protection might be required and contact should be made to the Picoso WSC Pipeline Inspection Department – Backflow Prevention Section for a determination.

4-3.2 Water Service Application

The customer's application for water service shall include a mechanical layout or general provisions as outlined in the Picoso WSC Backflow Prevention Control Program. If the size and type of assembly is not

shown, the Picoso WSC Pipeline Inspection Department will specify. Upon installation and testing of the approved backflow prevention assembly or Air Gap arrangement, a record of the installation will be made by the Picoso WSC.

4-3.3 Customer Service Inspections

In accordance with the Texas Commission on Environmental Quality's rules which became effective 1999, a customer service inspection certificate shall be completed prior to providing continuous water service to new construction on any existing service when the water purveyor has reason to believe that Cross-connections, other unacceptable plumbing practices exist, or after any material improvement correction or addition to the private plumbing facilities is made.

In areas not having access to plumbing inspections, the Picoso Water Supply Corp. will require a Customer Service Inspection Certificate to be completed by a Customer Service Inspector or Water Supply Protection Specialist prior to the Picoso WSC providing continuous water service. The inspection shall include all backflow prevention assemblies installed on the various Cross-connection health hazards. The plumbing final must include provisions for Cross-connection control and backflow prevention and lead regulation compliance as outlined in national plumbing codes and the Environmental Protection Agency.

4-4 Procedures On Existing Facilities

In the case of an existing service, the following general procedures will be utilized.

4-4.1 Inspection Procedure – Water Use Survey

After complete premise inspection by the Picoso WSC Backflow Prevention Inspector, a formal written notice advising of backflow prevention assembly requirements will be issued to the owner or lessee of an establishment or premise. The notice will contain the following: List of approved assemblies, set of backflow prevention assembly installation standards and a list of licensed testers.

4-4.2 Picoso Water Supply Corp. Planning and Development Services Department of Building Inspections – Permit Approval

Plans submitted to the Picoso Water Supply Corp. Planning and Development Services Department for approval on plumbing modifications or additions to an existing establishment or residence will

be reviewed by the Picoso WSC to determine the type of backflow preventer required for the entire establishment. The type of backflow preventer will be noted on the plans for approval: Notice of Requirement, a list of Approved Assemblies, Set of Backflow Prevention Assembly Installation Standards and list of Licensed Testers.

4-4.3 Picoso Water Supply Corp. Counter Services

Any customer request for a change on an existing commercial service or on an existing residential service where the change is due to a lawn sprinkler installation will be routed through the Pipeline Inspection Department's Backflow Prevention Section to ensure compliance of Section 4-3 Procedure on New Facilities above.

4-4.4 Picoso Water Supply Corp. Customer Service Department

Each request for a new commercial service to be placed through an existing service connection will be reviewed by the Pipeline Inspection Department's Backflow Prevention Section to ensure compliance with this Cross-connection Control and Backflow Prevention Program.

4-5 Installation

The backflow prevention assemblies and air gap separation shall be installed in accordance with the Backflow Prevention Assembly Installation Standard, attached hereto.

4-5.1 Size of Assembly

This program does not regulate the size of backflow preventers. However, the containment backflow prevention assemblies required will generally be the same size as the meter requirement stipulated by the Picoso Water Supply Corp. Requirements & Program Division. Backflow Prevention Assemblies must be sized in accordance with local plumbing code requirements. *Exception:* Irrigation systems could exceed the flow capacity of the water service meter. Make sure to size the pipe and backflow preventer accordingly.

4-5.2 By-pass Policy

If a By-pass is installed around the approved backflow prevention assembly, the distribution system must be protected from a backflow through this By-pass, i.e., it also will include a backflow preventer of the same type as the main service line backflow preventer. Though it need not be of the same size, it must be installed and tested in a similar fashion to the service line assembly so as to provide the same degree of protection as the main service line.

4-5.3 Critical Service

During the engineering process of determining types of water service, consideration should be given to the critical need of water to the site. This could relate to fire protection or potable water thus requiring the possible duplication of services so water can be maintained to the site at all times.

4-6 Non-Compliance

In any case of non-compliance or violation of the Picoso WSC System Criteria or the County Code, the Picoso WSC Director of Pipeline Inspections shall disconnect or discontinue service to a non complying customer subject to proper notice to the customer.

4-7 Records and Tests

In order to assure that backflow prevention assemblies continue to operate satisfactorily, it will be necessary that tests be conducted in accordance with desired performance standards. All tests and repairs shall be performed by a Licensed Tester. The original Test and Maintenance Report form will be completed by the licensed tester and submitted to the Picoso WSC Pipeline Inspection Department for record. It will be the responsibility of the customer to initiate the testing and any maintenance necessary and to submit written results to the Picoso WSC Pipeline Inspection Department.

4-7.1 Time Schedule

All backflow prevention assemblies must be tested at the time of installation, at the time of any repairing or relocation and at the completion of each year of service.

4-7.2 Testing by Picoso Water Supply Corp.

Picoso Water Supply Corp. personnel may perform periodic tests on backflow prevention assemblies at random locations, as authorized in the latest edition of the International Plumbing Code and local amendments, so as to ensure that acceptable tests are being followed by the Licensed Tester. Additionally, assemblies will be randomly selected and tagged in a manner that will determine if the assembly has been tested as required. Failure to comply could result in tester removal and possible litigation.

4-8 Cross-connection Control Liaison Committee

The Cross-connection Control Liaison Committee will consist of personnel from the Picos Water Supply Corp. , a Registered Professional Engineer, a Licensed Plumber, a Mechanical Engineer.

4-9 Costs

All costs associated with the subject program are to be borne by the customer. This includes the initial purchase of the backflow prevention assembly, its proper installation, testing and maintenance. Advisory assistance may be requested at any time from the Picos WSC Pipeline Inspection Department without charge.


4-10 Process Flow Charts

4-10.1 Cross-Connection Control and Backflow Prevention Process



San Antonio Water System
 Backflow Prevention
 Cross Connection and Backflow Prevention Control
 Program Guidelines

715.08
 4-10



NOTE:
 (1) For properties located outside the proposed limits (OCL) of San Antonio, USAR receives both the internal and external Backflow Prevention report information. To make the external Backflow Prevention report information available to the internal Backflow Prevention specialists.

4-10.2 Customer Service Inspection Process

I. GENERAL INSTRUCTIONS

1. Assemblies will be installed in an accessible location to facilitate maintenance, testing and repair, and should be located no more than five feet above the floor or grade level. The backflow preventer must be installed between the meter and before the owner's first tap or tee (total containment) unless otherwise approved. Internal containment will be approved for car washes, schools, retail laundries, and multiple lease spaces by individual review. In no instances will the assembly be allowed in the same vault with the Picoso WSC water meter. Containment assemblies on fire lines must be located within 100' (pipe length) of the property line.
2. Vault lids will be constructed in such a manner as to permit easy accessibility at all times by an individual. Vaults deeper than five feet shall be provided with a ladder permanently attached to a side wall. It is the contractor and owner's obligation and responsibility to ensure OSHA regulations are adhered to in the construction of all vaults. Additionally, confined space regulations are to be consulted and followed in the testing and maintenance of the backflow prevention assemblies.
3. Before installing the assembly, pipelines should be thoroughly flushed to remove foreign material.
4. Test cocks must never be used as supply connections and must be plugged except when testing. Plugs must be non-ferris, e.g., brass, plastic, etc. Backflow preventers must be installed horizontally and in an upright position, unless full approval has been obtained from the University of Southern California or the American Water Works Association. Future testing and repair on backflow prevention assemblies require the indicated clearances to be provided regardless of test cock locations except for 1" or smaller double check valve assemblies that are repairable from the top. have test cocks on top of the assembly and not installed in concrete or asphalt.
5. All hot water heating systems should be evaluated before the backflow prevention assembly is installed to ensure that a Thermal Expansion Tank has been properly installed and in working condition. Future backflow prevention assembly tests should also include the testing of pressure relief valves.
6. In order to ensure that backflow prevention assemblies continue to operate satisfactorily, it will be necessary that they be tested at the time of installation and on an annual basis thereafter. Such tests will be conducted in accordance with Picoso WSC performance standards and field test procedures as prescribed by the American Water Works Association or the University of Southern California. The Backflow Prevention Section shall provide appropriate "test and maintenance" report forms.
7. The Backflow Prevention Section will inspect all containment installations, i.e., located between the water meter and before the owner's first tap or tee.
8. All costs entailed in the subject program are to be borne by the customer. This includes the initial purchase of the backflow preventer, its proper installation, testing and maintenance. Both containment and internal isolation backflow preventers must be maintained in good working condition.

II. INSTALLATION OF REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTERS

Reduced pressure principle backflow preventers will be installed above ground. (Fig. A) The unit should be placed at least 12 inches (12") above the finish grade to allow clearance for repair work. A concrete slab at finish grade is recommended. Proper drainage should be provided for the relief valve and may be piped away from the

location, provided it is readily visible from above grade and the relief valve is separated from the drain line by a minimum of double the diameter of the supply line. A modified vault installation may be used if constructed with ample side clearances. (Fig. B) Freezing can be a problem in this area and precautions should be taken to protect above ground installations. Refer to local fire and plumbing codes to find insulating requirements for backflow prevention assemblies.

ABOVE GROUND INSTALLATION




FIG. A





FIG. B

III. INSTALLATION OF DOUBLE CHECK VALVE ASSEMBLY BACKFLOW PREVENTER

Though double check valve assemblies can be installed above ground, these backflow preventers are also readily adaptable for vault installations. Special notice should be given to the side clearances for accessibility to properly test and repair the assembly. Test cocks must be plugged. Plugs must be non-ferrous, e.g., brass, plastic, etc. NOTE SIDE CLEARANCES, (Fig. C) (See General Instructions, page 1)


VAULT INSTALLATION



TOP VIEW

CLEARANCES ON TEST COCK,
SIDE OF DEVICE (See Gen. Ins.)
3/4" THRU 2" - 12" MIN. *
3" AND UP - 24" MIN.
MIN. VAULT WIDTH 3" AND UP - 4" I.D.

* SEE II A - 3/4" THRU 2"
** SEE V - BY-PASS POLICY



SIDE VIEW

Fig. C

A. BELOW GRADE VAULT INSTALLATION OF DOUBLE CHECK VALVE ASSEMBLY


Double check valve assemblies should be installed above grade if possible, but may be installed in below grade vaults when these vaults are properly constructed in accordance with the following guidelines:

I. General – Double Check Valve Assemblies – All Sizes

Double check valve assembly backflow preventers, unlike reduced pressure principle assemblies, are designed and readily adaptable for below grade installations, provided they are installed in a vault which is well drained and of solid construction. Vaults within traffic areas should be constructed accordingly. Assemblies must be installed horizontally and in an upright position. Backflow preventers installed in a vertical position if approved by USC FCCCHR will also be allowed.

II. Double Check Valve Assemblies Sizes 3/4" through 2"

Backflow preventers of sizes two inches and less should not be installed more than 12" below grade for accessibility during testing and repair. To accommodate the installation of most double check valve assemblies up to and including two inch sizes, a vault constructed of concrete, steel, cast iron or other durable material conforming to the dimensions described below is acceptable provided a twelve inch (12") clearance is maintained on the test cock side of the assembly (see General Instructions No. 4), a four inch (4") clearance on the non-test cock side and a four inch (4") clearance between the two gate valves and the ends of the vault. Exception: On 1" or smaller double check valve assemblies that are repairable from the top, have test cocks on the top of the assembly and not installed in cement or asphalt, the side clearance can be reduced to 4", see General Instructions No. 4. The floor of the vault shall be either of solid construction with a drain or bottomless to facilitate drainage. In order to facilitate repair of Y-pattern assemblies, a twelve inch (12") clearance must be provided below the assembly. Rigid construction must extend to the floor of the vault.



IV. INDOOR INSTALLATION – REDUCED PRESSURE AND DOUBLE CHECK VALVE ASSEMBLY BACKFLOW PREVENTERS

Where it is impractical to install the backflow preventer above ground, the installation may be made in an easily accessible location inside a building. The unit should be placed above the floor and away from the wall at a distance great enough to allow clearance for repair work. If the backflow preventer is positioned against the wall, care should be taken that the test cocks are easily accessible for testing, and the assembly can be repaired. An air gap should be used between the relief valve outlet and the drain line if drainage is to be piped away. The drain should be of adequate size to carry the volume of water the relief valve is capable of discharging. The air gap should be no less than double the diameter of the discharge pipe. (Fig. D) (See General Instructions, Page 1)

INDOOR INSTALLATION




FIG D.

V. BY-PASS POLICY

Backflow prevention assemblies must be tested upon installation and on an annual basis thereafter. The testing procedure requires the water to be turned off. If continuous water service is a necessity, provisions should be made for a by-pass around the mainline backflow preventer. A by-pass installed around an approved backflow prevention assembly must be protected from backflow through this by pass, i.e., it also will include a backflow preventer of the same type as the main service line backflow preventer. Though it need not be of the same size, it must be installed in a similar fashion to the service line device.

VI. AIR GAP SEPARATION (A/G)

An air gap separation means the unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe or faucet supplying water to a tank, plumbing fixture or other device and the flood level or overflow rim of the receptacle. An "approved air gap separation" shall be at least double the diameter of the supply pipe measured vertically above the overflow rim of the vessel and in no case shall the gap be less than 1." The tank should be installed as close to the property line as practical. The piping between the water meter and the air gap separation should be entirely visible to ensure that no connections or tees are made in that area. To eliminate possible entrance of vermin, screened protections over the entire (A/G) set up are encouraged. (See General Instructions, Page 1)

AIR GAP SEPARATION





FIG E.

VII. LAWN SPRINKLER INSTALLATION USING A PRESSURE TYPE VACUUM BREAKER AS A BACKFLOW PREVENTER

Pressure type vacuum breakers may be installed without regards to downstream valve, making it possible to isolate an entire lawn sprinkler system with a single unit when properly located. This assembly must not be installed where it will be subject to backpressure and should be installed at least twelve inches (12") above the highest outlet. The vacuum breaker should be installed where it will be accessible for periodic testing and where, if slight spillage should occur, it would not be objectionable. (Fig. F) (See General Instructions, Page 1). If chemical additives are to be used, an air gap separation or reduced pressure principle assembly will be required.



(Residential Only)

BACKFLOW PROTECTION FOR WATER HAULING EQUIPMENT AND/OR MIXING TANKS

1. PURPOSE

The following information is provided in the interest of protecting the potable water system from actual or potential contamination through cross connections and backflow situations. A cross-connection is any connection between the potable water supply and another water supply of unknown quality or any source, which may contain contaminating or polluting substances. All water hauling equipment and/or potable water mixing tanks using water from fire hydrants or any other type outlet must use one of the backflow prevention methods described herein to adequately protect the potable water system.

2. GENERAL REQUIRMENTS

- a. The customer must contact the Picoso WSC Backflow Prevention section of the Pipeline Inspections Department at (830) 393-44 24 prior to water usage to request an inspection of the on-site backflow protection installed. Requests made between 8am and 11am should normally result in same day inspections, otherwise the inspections will be made the following business day, consistent with operational requirements.
- b. Customers electing to permanently install an air gap separation on water transporting vehicle(s) must have the air gap separation inspected and approved by the Backflow Prevention Section.
- c. Customers electing to install a reduced pressure principle backflow assembly will be required to have the assembly tested by a licensed backflow prevention assembly tester upon installation and minimum of annually thereafter.

3. BACKFLOW PREVENTION METHODS

The customer shall provide one of the approved methods for backflow protection described below and as further illustrated in the attached drawings marked as figures A through D. The customer shall also consult the San Antonio Water System list of approved assemblies and installation guidelines.

- a. Air gap separation provided by a metallic pipe permanently installed on the water transporting vehicle will serve as a fill line and also include a hose connection to the potable water outlet. Note figure A.
- b. Air gap separation installed on the outlet side of the fire hydrant meter. Note figure B.
- c. Reduced Pressure Principle (R/P) backflow prevention assembly installed at the fire hydrant meter. Note figure C.
- d. Reduced Pressure Principle (R/P) backflow prevention assembly permanently installed on the water-transporting vehicle. Note figure D.





Figure A



Must have Signs Stating
"Caution: Non-Potable Water.
Do not Drink the Water
NO TOMAR EL AGUA"

The Letters must be
3" inches in size and
Must be visible on three (3)
sides of the Water Tank.
The signs must be in
English and Spanish

Figure B

Picosa Water Supply Corp.

Backflow Prevention

Standard Drawing Detail Information

SPECIFICATIONS LOOK FOR THE DESIRED DETAILED DRAWING BY
THE DD NUMBER.

OR

CONTACT Picosa Water Supply

AT

Backflow Section
Picosa Water Supply Corp
3274 FM-2579
Floresville, Texas
(830)393-4424